

APPENDIX K
Inspection Report for a Single Family Waste
Stabilization Pond - Short Form

Name of Owner _____

Address of Owner _____

Person(s. Contacted At Site _____ Phone No. _____

Section ____, Township ____, Range ____, County _____

Number of Occupants Served _____, Number of Bedrooms ____

Approximate Vertical Distance, water level to top of dike _____

REVIEW; Mark pond deficiencies; provide any necessary details on back:

1. Pond used by more than one household
2. Pond construction incomplete or substandard
3. Pond not sized according to plans and specifications
4. Pond area not fenced and/or gated according to plans & specifications
5. Pond within 100 feet of well
6. Pond too close to property line
7. Evidence of irrigation used routinely for effluent disposal or evidence of pond discharging
8. Surface drainage into pond
9. Dikes eroded, damaged, sloped steeper than 3 1/2 to 1, or in need of modification
10. Pond dikes and berm not mowed; trees growing and/or vegetation height more than 6 inches
11. Poor stand of groundcover on dikes and berm
12. Cattails, trees or other rank weed growth in pond
13. Other (include anaerobic condition.

Name: _____

Date: _____ Title: _____